


SAFE DRINKING WATER CERTIFICATE

Date:- 18/05/2020

Ref:- 1136

It is certified that, drinking water of Shantikunj Public School ,Court Area Jehanabad has been found safe, healthy and clean for the Students and staffs of the institution. The school is maintaining the hygienic condition in the building and its campus as per the norms prescribed.


Signature with seal:-
Executive Engineer
P.H. Division Jehanabad

Name :- SANJAY KUMAR

Designation:- EXECUTIVE ENGINEER



बिहार सरकार

Govt. of Bihar
District Level Water Testing Laboratory Jehanabad.
P.H.Division Jehanabad.
Swami Sahjanand Nagar Jehanabad. . PIN- 804408

TEST REPORT

Name & Address Of the Customer : Shantikunj Public School		Date of Reporting	16-05-2026
Block:	Jehanabad	Sample Description	Drinking Water
Panchayat:	Nagar Panchayat		
Village:	Court Area	Sample Mark/ Location	Court Area
Ward No.:	31	Sample Submitted in Lab On	13-05-2026
Location:	Ground Water	Sample Submitted by	Self
		Date of Completion of Test	16-05-2026
		Ref No. Date	

Analysis Result

Sl. No.	Test Parameter	Test Method	IS 10500:2012Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	Colour (HU)	IS 3025 (Part 4) : 2021	5	15	<5
2	Odour	IS 3025 (Part 5) : 2022	Agreeable	NR	Agreeable
3	Taste	IS 3025 (Part 8) : 2023	Agreeable	NR	Agreeable
4	pH at 25 °C	IS 3025(Part 11) : 2022	6.5	8.5	7.72
5	Turbidity (NTU)	IS 3025(Part 10) : 2023	1	5	0.3
6	TDS (mg/l)	IS 3025(Part 16) : 2023	500	2000	396
7	Total Hardness (mg/l)	APHA 24th Addition-2340 C: 2023	200	600	154.44
8	Calcium (mg/l)	APHA 24th Addition-3500 Ca B: 2023	75	200	43.17
9	Magnesium (mg/l)	APHA 24th Addition-3500-Mg Method B : 2023	30	100	10.94
10	Chloride (mg/l)	IS 3025(Part 32) : 2019	250	1000	46.27
11	Total Alkalinity (mg/l)	IS 3025(Part 23) : 2023	200	600	118.32
12	Iron (mg/l)	APHA 24th Edition -3500-Fe Method B : 2023	1.00	NR	0.20
13	Bacteria	H2s Vial	-ve	-ve	-ve

****End Of Report****

Disclaimer:

- The result relates only to the item(s) tested.
- The report shall not be reproduced except in full, without approval of the laboratory.
- The reserved part of water sample(s) shall be retained for 15 days from the date of issue of the report.
- The results apply to the sample as received.

For District Level Water Testing Laboratory, Jehanabad.

Reviewed & Authorized By

Amit Kumar
18/05/26

Name :Mr. Amit Kumar.
(Authorized Signatory)